



D.B. Wilson Station
5663 State Route 85 West
Centertown, KY 42328
www.bigrivers.com

October 8, 2020

Re: Big Rivers Electric Corporation D.B. Wilson Station Landfill (AI 3319) Notification of Statistical Exceedance above the Groundwater Protection Standard

Additional Appendix IV constituent(s) were detected at a statistical significant level above the established groundwater protection standard during assessment monitoring at the above referenced CCR unit. Cobalt at monitoring well MW-5 and MW-6 showed an exceedance of the groundwater protection standard.

Big Rivers Electric Corporation D.B. Wilson Station is supplying this document as formal notification and in accordance with 40 C.F.R §257.96 and 40 C.F.R. §257.97, the Appendix IV constituent(s) listed above will be included for consideration in the assessment of corrective measures and selection of remedy process.